

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1062:132

Page 1 of 1

CATEGORY: Control Unit/Household

LISTEE: Detection Systems, Inc., 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (716) 223-4060

DESIGN: Model DS7080iP32 residential fire alarm control unit. Refer to listee's printed data sheet for additional detailed product description and operational considerations. System components:

DS7080iP32	Control Panel
DS7433, DS7445, DS7447	Keypad
EX8	8-Zone Expansion Module
DS7481	Single Phone Line Monitor
DS7488	Relay Board
DS7480	Bell Supervisory Board

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as residential fire alarm control units for use with separately listed compatible initiating and indicating devices.

NOTE:

1. Burglary and other non-fire functions were not examined.
2. Fire **Alarm Verification Feature** (delay of fire alarm) shall not be used in California.

07-24-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 19, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager